



- NOTES:**
- INSULATE THE FOLLOWING EXISTING HEAT TRACED PIPING: (REFER TO SPECIFICATION SECTION 15250)
 - TRANSFER LINE FROM SULFURIC ACID DRUM
 - RECIRCULATION PUMP DISCHARGE (BOTH TOWERS)
 - RECIRCULATION PUMP AND PUMP SUCTION (BOTH TOWERS)
 - SODIUM HYDROXIDE LINES
 - SODIUM HYPOCHLORITE LINES
 - EXISTING SUPPORT STRUCTURE NOT SHOWN. REFER TO SPECIFICATION SECTION 11583.
 - INSTALL EXISTING AND NEW FANS WITH CENTERLINE OF FAN INLET ALIGNED TO THE CENTERLINE OF THE DUCTWORK. REPLACE TRANSITION FITTING WITH CONCENTRIC REDUCER.
 - REMOVE SUMP PUMP DISCHARGE PIPING. CAP OPENINGS WHERE PIPING IS REMOVED. REMOVE SUMP PUMPS, CHECK VALVES AND SHUTOFF VALVES AND TURN OVER TO OWNER.
 - ADDITIONAL EXISTING PIPING TO BE INSULATED. REFER TO SPECIFICATION SECTION 15250.
 - EXISTING DUCTWORK IS SCREENED BACK. NEW DUCTWORK IS SHOWN IN BOLD.
 - REMOVE AND STORE EXISTING STACK AND SUPPORT STRUCTURE. PREVENT ANY DAMAGE TO STACK AND SUPPORT STRUCTURE. DEMOLISH EXISTING PIERS FOR SUPPORT STRUCTURE PER 3273
 - PROVIDE NEW PIERS 18"x14" PER 3356H SIM AT HEIGHT TO SUIT STACK AND FAN REALIGNMENT PER NOTE 3.
 - INSTALL NEW STACK AND SUPPORT STRUCTURE AND REINSTALL EXISTING STACK AND SUPPORT STRUCTURE ON NEW PIERS.

THESE RECORD DOCUMENTS HAVE BEEN PREPARED BASED ON THE INFORMATION PROVIDED BY OTHERS. THE DESIGN PROFESSIONAL HAS NOT VERIFIED THE ACCURACY AND/OR COMPLETENESS OF THIS INFORMATION AND SHALL NOT BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS WHICH MAY BE INCORPORATED HEREIN AS A RESULT.

MODIFICATIONS TO EXISTING ODOR CONTROL SYSTEM

1/4"=1'-0"

RECORD DRAWING		APVD	B. GACKSTATTER
RE-ISSUED FOR CONSTRUCTION		BY	B. GACKSTATTER
ISSUED FOR CONSTRUCTION		BY	B. GACKSTATTER
FOR FINAL REVIEW/ BUILDING PERMIT		BY	B. GACKSTATTER
NO.	REVISION	CHK	APVD
3	01/20/08	S. LAROCQUE	M. RAHMAN
2	09/09/06	S. LAROCQUE	B. GACKSTATTER
1	07/04/06	S. LAROCQUE	B. GACKSTATTER
0	06/05/06	S. LAROCQUE	B. GACKSTATTER
DSGN	DATE	DR	APVD
STAMFORD WPC		STAMFORD WPC	
STAMFORD WATER POLLUTION CONTROL AUTHORITY		STAMFORD WATER POLLUTION CONTROL AUTHORITY	
SOLIDS DRYING PROJECT		SOLIDS DRYING PROJECT	
BUILDING SERVICES		BUILDING SERVICES	
ODOR CONTROL		ODOR CONTROL	
MODIFICATIONS TO EXISTING		MODIFICATIONS TO EXISTING	
ODOR CONTROL SYSTEM		ODOR CONTROL SYSTEM	
VERIFY SCALE			
BAR IS ONE INCH ON ORIGINAL DRAWING.			
DATE	JUNE 2006		
PROJ	334058		
DWG	B-2401		
SHEET	B3		